ADDENDUM #2

Owner:
Montana State University
Facilities Management
Owner Rep: Donny Beebe
Project Manager, PDC

Architect:
Architects Alaska, Incorporated
347 S Ferguson Ave, Suite 3
Bozeman, Montana 59718
Project Architect: Thomas Brown

NOTICE TO BIDDERS

This Addendum is issued pursuant to the Instructions to Bidders. This Addendum serves to clarify, revise, and supersede information in the Contract Documents and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.

The Bidder shall acknowledge receipt of this Addendum on the Bid Form.

The Date for receipt of bids is unchanged.

BIDDER QUESTIONS

Question 1 **Are the double doors between Extruder Room 132A, and Hall 133 fire rated?**

Answer 1 No.

Question 2 **Is the intent for the existing hardware (including closers and hinges) to be reused? Or is the new hardware preferable?**

Answer 2 If the existing hardware is salvageable and functions properly with the flipped orientation then reusing hardware is preferred.

Question 3 **What kind of hold-open hardware do you have in mind? (door stop, arm, etc.)**

Answer 3 Hold-open hardware is removed from the project scope.

ATTACHMENTS

NONE

END OF ADDENDUM